

April 15, 2021

POLK COUNTY, A POLITICAL SUBDIVISION OF THE STATE OF FLORIDA

ADDENDUM #2

RFP 21-473, Lake Pierce Ranchettes Park Playground Installation

This addendum is issued to clarify, add to, revise and/or delete items of the RFP Documents for this work. This Addendum is a part of the RFP Documents and acknowledgment of its receipt should be noted on the Addendum.

Contained within this addendum: questions and answers

Danielle Rose
Procurement Analyst
Procurement Division

This Addendum sheet should be signed and returned with your submittal. This is the only acknowledgment required.

Signature: _____

Printed Name: _____

Title: _____

Company: _____

RFP 21-473, Lake Pierce Ranchettes Park Playground Installation Addendum #2 (Continued)

Questions & Answers:

Question 1: Will the County be extending the submission deadline since the footprint has only just been confirmed?

Answer 1: No, the footprint change was only to add more space for the swings due to concerns brought up at the mandatory pre-bid.

Question 2: What is the wind load required for a shade on a structure to not be taken off?

Answer 2: Wind design criteria is found in 2017 Florida Building Code 6th ed 16-32

1. Ultimate wind speed 140 MPH
2. Occupancy Category – Playground
3. Wind Importance Factor 1.0
4. Wind Exposure Category: C
5. Internal Pressure Coefficient -N/A (open Structure)
6. Enclosure Classification: open
7. Components and Cladding (PSF): 25.0 to -25.0
8. Risk Category II

Question 3: Please clarify 30 percent rule as far as shade to a structure how is that determined?

Answer 3: Please refer to Addendum 1: Clarification bullet 4 & Question & Answer 10.